



Share your feedback
about this standard.
Scan the QR code on your
phone or click/ enter the
link to take the survey
feedback.standards.org.au/2293.1:2018

AS/NZS 2293.1:2018
(Incorporating Amendment No. 1)

AS/NZS 2293.1:2018

Australian/New Zealand Standard™

**Emergency lighting and exit signs for
buildings**

**Part 1: System design, installation and
operation**



AS/NZS 2293.1:2018

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee LG-007, Emergency Lighting in Buildings. It was approved on behalf of the Council of Standards Australia on 5 June 2018 and by the New Zealand Standards Approval Board on 3 April 2018.
This Standard was published on 29 June 2018.

The following are represented on Committee LG-007:

Australasian Fire and Emergency Service Authorities Council
Australian Building Codes Board
Australian Industry Group
Business New Zealand
Electrical Trades Union
Employers Chamber of Commerce Central
Engineers Australia
Fire Protection Association Australia
IES: The Lighting Society
Lighting Council Australia
Lighting Council New Zealand
Ministry of Business, Innovation and Employment, New Zealand
National Electrical and Communications Association
Property Council of Australia
Queensland University of Technology
University of Sydney
WorkSafe New Zealand

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Site at www.standards.org.au or Standards New Zealand web site at www.standards.govt.nz and looking up the relevant Standard in the on-line catalogue.

For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of Standards Australia or the New Zealand Standards Executive at the address shown on the back cover.

This Standard was issued in draft form for comment as DR AS/NZS 2293.1:2018.

AS/NZS 2293.1:2018
(Incorporating Amendment No. 1)

Australian/New Zealand Standard™

Emergency lighting and exit signs for buildings

Part 1: System design, installation and operation

Originated in Australia as AS 2293.1—1979.
Originated in New Zealand as NZS 6742.1:1971.
Previous New Zealand edition AS/NZS 2293.1:1998.
Previous Australian edition AS 2293.1—2005.
Jointly revised and designated AS/NZS 2293.1:2018.
Reissued incorporating Amendment No. 1 (May 2021).

COPYRIGHT

© Standards Australia Limited

© The Crown in right of New Zealand, administered by the New Zealand Standards Executive

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Australia) or the Copyright Act 1994 (New Zealand).

ISBN 978 1 76072 135 0

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee LG-007, Emergency Lighting in Buildings, to supersede AS 2293.1—2005, *Emergency escape lighting and exit signs for buildings, Part 1: System design, installation and operation*.

This Standard incorporates Amendment No. 1 (May 2021). The changes required by the Amendment are indicated in the text by a marginal bar and amendment number against the clause, note, table, figure or part thereof affected.

The AS/NZS 2293 series comprises three Parts as follows:

AS/NZS

- 2293 Emergency lighting and exit signs for buildings
- 2293.1 Part 1: System design, installation and operation (this Standard)
- 2293.2 Part 2: Inspection and maintenance
- 2293.3 Part 3: Emergency luminaires and exit signs*

The objective of the AS/NZS 2293 series of Standards is to provide those associated with the design, construction, installation, certification and maintenance of all the individual components of an emergency lighting and exit signage scheme, and the scheme as a whole, with the requirements and guidelines to provide an installation that will ensure an acceptable level of illumination to the nominated areas for the safe evacuation of occupants from those areas in an emergency situation.

The objective of this Standard is to provide designers, installers and certifiers of emergency lighting and exit signage schemes with the relevant requirements and guidance for the provision of emergency lighting and exit signs to all designated spaces within a building in order to ensure an acceptable level of illumination for the safe evacuation of occupants from those spaces in an emergency situation.

The principal reason for this edition of the Standard is to specify updated installation requirements and adapt the Standard to current technologies, terminologies and delete out of date references or methods. Many of the section headings have been re-worded to better reflect their application and the sections re-ordered to assist in the reading of the document. Spacing tables have been moved to a normative appendix.

To assist with the application of this Standard, definitions have also been included for the following:

- (a) Exit signs—Four types defined.
- (b) High risk task area lighting.
- (c) Light source(s).
- (d) Remote self-contained emergency luminaire or exit sign.
- (e) Stand-by lighting.

Further to these items some other definitions have been revised to support these new definitions or to clarify previous ambiguities.

The terminology now used recognizes the term ‘emergency lighting’ as including four categories of lighting, each provided with an alternative energy supply, as follows:

- (i) Emergency evacuation and emergency escape lighting.
- (ii) Illuminated emergency exit signs.
- (iii) High risk task area lighting.

(iv) Stand-by lighting.

Of these categories, Items (i) and (ii) refer to the two types of emergency lighting that are required by the deemed-to-satisfy provisions of the NCC and New Zealand Building Code and comprise the scope of the AS/NZS 2293 series of Standards. Items (iii) and (iv) are not covered by this series of Standards. However, definitions for these types of lighting have been added to this edition of the Standard.

Some clauses have been moved to assist reading and application of the Standard. For example, the clauses titled 'Avoidance of obstruction of light', 'Avoidance of glare' and 'Protection against unauthorized removal of lamps' have been moved into a 'General' clause in Section 4, which deals with installation requirements for emergency luminaires. The clause specifying the illumination requirements has been moved to Clause 4.2, titled 'Provision of emergency luminaires' rather than within the specific clauses dealing with illuminance calculations.

Clause 2.3.3, dealing with sensing of supply failure, has been simplified and the methodologies aligned for both central battery and single point emergency lighting systems.

AS/NZS 2293.3 requires an emergency luminaire to be classified according to its ability to achieve a luminous intensity up to a 70 degree cut off angle for Classification A-D (65 degrees for Classifications E). The calculations for the classification currently do not assess the contribution of luminance beyond this 70 degree geometric limit. AS 2293.1 contains spacing tables for common mounting heights for emergency luminaires based on their classification (derived from AS/NZS 2293.3) to achieve the current minimum at floor level. However, having regard only for the light assessed under the 70 degree geometric limitation used for the purpose of classifying the luminaire, calculations reveal the previous edition's spacing tables allow configurations that would result in the current minimum not being achieved. Further, with changing technology, unlike fluorescent and incandescent types typical of the available light sources at the time of publication of previous editions of this Standard, some luminaires including modern LEDs do not produce light beyond their assessed geometric limitation and therefore may not achieve the current minimum at all points on the floor.

This edition contains a set of revised classification tables to reflect maximum spacing that does not exceed geometric limitations of 70 degrees for all Class A-D luminaires and 65 degrees for Class E luminaires assessed under AS/NZS 2293.3. Two sets of tables are contained within Appendix E and F. Appendix E contains tables based on 0.2lx minimum between emergency luminaires and Appendix F contains tables based on 1lx minimum between luminaires. It also includes, in the calculation method, a requirement to achieve a 'minimum average' of 0.5 lx in addition to the current minimum.

The use of spacing tables for stairwells has been revised and simplified. Rather than modifying spacings using a set of rules, to achieve the higher illumination levels required in stairs, and spacing tables based around 0.2lx minimum, emergency luminaires are selected using the conventional spacing table approach based on the new spacing tables in Appendix F based on 1lx minimum.

This edition of the Standard requires that emergency luminaires and exits signs are visibly labelled and previous inconsistencies between the information required for maintaining the system and references to requirements prescribed in AS/NZS 2293.2 have been identified and corrected.

Provisions and requirements for centrally supplied systems have been simplified and upgraded. Within buildings required to be constructed of fire-resisting elements there are no longer separate provisions for buildings supplied with automatic sprinkler systems compared to buildings without. The class of cable protection has been standardized to be WS4X protection and the fuse type within terminal boxes has been widened to include fuses

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- Looking for additional Standards? Visit Intertek Inform Infostore
 - Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation
-