This is a free page sample. Access the full version online.

NSAI Standards

Irish Standard
I.S. EN 16798-5-2:2017

Energy performance of buildings - Ventilation for buildings - Part 5-2: Calculation methods for energy requirements of ventilation systems (Modules M5-6, M5-8, M6-5, M6-8, M7-5, M7-8) - Method 2: Distribution and generation

© CEN 2017 No copying without NSAI permission except as permitted by copyright law.

This is a free page sample. Access the full version online.

I.S. EN 16798-5-2:2017

Incorporating amendments/corrigenda/National Annexes issued since publication:

The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:

I.S. xxx: Irish Standard — national specification based on the consensus of an expert panel and subject to public consultation.

S.R. xxx: Standard Recommendation — recommendation based on the consensus of an expert panel and subject to public consultation.

SWiFT xxx: A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

This document replaces/revises/consolidates the NSAI adoption of the document(s) indicated on the CEN/CENELEC cover/Foreword and the following National document(s):

NOTE: The date of any NSAI previous adoption may not match the date of its original CEN/CENELEC document.

This document is based on:	*Published:*
EN 16798-5-2:2017	2017-08-16

This document was published under the authority of the NSAI and comes into effect on:	ICS number:
2017-09-04	91.120.10 91.140.30 NOTE: If blank see CEN/CENELEC cover page

NSAI 1 Swift Square, Northwood, Santry Dublin 9	T +353 1 807 3800 F +353 1 807 3838 E standards@nsai.ie W NSAI.ie	Sales: T +353 1 857 6730 F +353 1 857 6729 W standards.ie

Údarás um Chaighdeáin Náisiúnta na hÉireann

This is a free page sample. Access the full version online.

National Foreword

I.S. EN 16798-5-2:2017 is the adopted Irish version of the European Document EN 16798-5-2:2017, Energy performance of buildings - Ventilation for buildings - Part 5-2: Calculation methods for energy requirements of ventilation systems (Modules M5-6, M5-8, M6-5, M6-8, M7-5, M7-8) - Method 2: Distribution and generation

This standard has been drafted so that it can be used in the context of national legal requirements and as such mandatory choices may be given at national level for specific applications. Default values for those parameters subject to national choice are listed in Annex B.

Currently this standard is being reviewed by the relevant national authorities after which a decision will be made on the use of the default values (Annex B) or otherwise.

Users of this Irish standard are advised to check for updates as to the status of the national decision in relation to the use of those values listed in Annex B.

This document does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

For relationships with other publications refer to the NSAI web store.

Compliance with this document does not of itself confer immunity from legal obligations.

In line with international standards practice the decimal point is shown as a comma (,) throughout this document.

This is a free page sample. Access the full version online.

This page is intentionally left blank

This is a free page sample. Access the full version online.

EUROPEAN STANDARD

NORME EUROPÉENNE

EUROPÄISCHE NORM

EN 16798-5-2

August 2017

ICS 91.120.10; 91.140.30

Supersedes EN 15241:2007

English Version

Energy performance of buildings - Ventilation for buildings - Part 5-2: Calculation methods for energy requirements of ventilation systems (Modules M5-6, M5-8, M6-5, M6-8, M7-5, M7-8) - Method 2: Distribution and generation

Performance énergétique des bâtiments - Ventilation des bâtiments - Partie 5-2 : Méthodes de calcul pour les besoins énergétiques des systèmes de ventilation (Modules M5-6, M5-8, M6-5, M6-8, M7-5, M7-8) - Méthode 2 : Distribution et génération

Energieeffizienz von Gebäuden - Modul M5-6.2, M5-8.2 - Lüftung von Gebäuden - Berechnungsverfahren für den Energiebedarf von Lüftungssystemen - Teil 5-2: Verteilung und Erzeugung (Revision von EN 15241) - Methode 2

This European Standard was approved by CEN on 27 February 2017.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

© 2017 CEN All rights of exploitation in any form and by any means reserved worldwide for CEN national Members.

Ref. No. EN 16798-5-2:2017 E

This is a free page sample. Access the full version online.

Contents

Page

European foreword ... 4

Introduction ... 7

1 Scope ... 9

2 Normative references ... 12

3 Terms and definitions ... 13

4 Symbols, subscripts and abbreviations ... 14
4.1 Symbols ... 14
4.2 Subscripts ... 14
4.3 Abbreviations ... 15

5 Brief description of the method — Output of the method ... 15

6 Calculation method ... 16
6.1 Output data ... 16
6.2 Calculation time interval and calculation period ... 17
6.2.1 Calculation interval ... 17
6.2.2 Calculation period ... 18
6.3 Input data ... 18
6.3.1 Source of data, general ... 18
6.3.2 Product data ... 18
6.3.3 System design data ... 21
6.3.4 Operating conditions ... 22
6.3.5 Constants and physical data ... 24
6.3.6 Input data from Annex A (Annex B) ... 24
6.4 Calculation procedure ... 24
6.4.1 Applicable time intervals ... 24
6.4.2 Operating conditions calculation ... 24
6.4.3 Energy calculation ... 29

7 Quality control ... 39

8 Compliance check ... 39

Annex A (normative) **Input and method selection data sheet — Template** ... 40
A.1 General ... 40
A.2 References ... 41
A.3 Input data ... 41
A.3.1 Product description data ... 41
A.3.2 Product technical data ... 42
A.3.3 System design data ... 44

Annex B (informative) **Input and method selection data sheet — Default choices** ... 48
B.1 General ... 48
B.2 References ... 49

This is a free page sample. Access the full version online.

B.3 Input data **49**
B.3.1 Product description data **49**
B.3.2 Product technical data **50**
B.3.3 System design data **52**

Bibliography **56**

This is a free page sample. Access the full version online.

European foreword

This document (EN 16798-5-2:2017) has been prepared by Technical Committee CEN/TC 156 "Ventilation for buildings", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by February 2018, and conflicting national standards shall be withdrawn at the latest by February 2018.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 15241:2007.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association.

Regarding the modifications that were made with regard to EN 15241:2007, these are listed in the last paragraph in the Introduction.

This standard has been produced to meet the requirements of Directive 2010/31/EU 19 May 2010 on the energy performance of buildings (recast), referred to as "recast EPDB".

EN 15241:2007 was produced to meet the requirements of Directive 2002/91/EC 16 December 2002 on energy performance of buildings referred to as "EPBD".

For the convenience of Standards users CEN/TC 156, together with responsible Working Group Convenors, have prepared a simple table below relating, where appropriate, the relationship between the 'EPBD' and 'recast EPBD' standard numbers prepared by Technical Committee CEN/TC 156 "Ventilation for buildings".

EPBD EN Number	Recast EPBD EN Number	Title
EN 15251	FprEN 16798–1[1)]	Energy performance of buildings — Part 1: Indoor environmental input parameters for design and assessment of energy performance of buildings addressing indoor air quality, thermal environment, lighting and acoustics — Module M1–6 (revision of EN 15251)
N/A	CEN/TR 16798–2	Energy performance of buildings — Ventilation for buildings — Part 2: Interpretation of the requirements in EN 16798-1 — Indoor environmental input parameters for design and assessment of energy performance of buildings addressing indoor air quality, thermal environment, lighting and acoustics (Module M1-6)

1) At voting stage by the time the present text is published.

This is a free page sample. Access the full version online.

EN 13779	EN 16798–3	Energy performance of buildings — Ventilation for buildings — Part 3: For non-residential buildings — Performance requirements for ventilation and room-conditioning systems (Modules M5-1, M5-4) (revision of EN 13779)
N/A	CEN/TR 16798–4	Energy performance of buildings — Ventilation for buildings — Part 4: Interpretation of the requirements in EN 16798-3 — For non-residential buildings — Performance requirements for ventilation and room-conditioning systems (Modules M5-1, M5-4)
EN 15241	EN 16798–5–1	Energy performance of buildings — Ventilation for buildings — Part 5-1: Calculation methods for energy requirements of ventilation and air conditioning systems (Modules M5-6, M5-8, M6-5, M6-8, M7-5, M7-8) — Method 1: Distribution and generation (revision of EN 15241)
EN 15241	EN 16798–5–2	Energy performance of buildings — Ventilation for buildings — Part 5-2: Calculation methods for energy requirements of ventilation systems (Modules M5-6, M5-8, M6-5, M6-8, M7-5, M7-8) — Method 2: Distribution and generation (revision of EN 15241)
N/A	CEN/TR 16798–6	Energy performance of buildings — Ventilation for buildings — Part 6: Interpretation of the requirements in EN 16798-5-1 and EN 16798-5-2 — Calculation methods for energy requirements of ventilation and air conditioning systems (Modules M5-6, M5-8, M6-5, M6-8 , M7-5, M7-8)
EN 15242	EN 16798–7	Energy performance of buildings — Ventilation for buildings — Part 7: Calculation methods for the determination of air flow rates in buildings including infiltration (Modules M5-5) (revision of EN 15242)
N/A	CEN/TR 16798–8	Energy performance of buildings — Ventilation for buildings — Part 8: Interpretation of the requirements in EN 16798-7 — Calculation methods for the determination of air flow rates in buildings including infiltration (Module M5-5)
EN 15243	EN 16798–9	Energy performance of buildings — Ventilation for buildings — Part 9: Calculation methods for energy requirements of cooling systems (Modules M4-1, M4-4, M4-9) — General (revision of EN 15243)
N/A	CEN/TR 16798–10	Energy performance of buildings — Ventilation for buildings — Part 10: Interpretation of the requirements in EN 16798-9 — Calculation methods for energy requirements of cooling systems (Module M4-1,M4-4, M4-9) — General
EN 15243	EN 16798–13	Energy performance of buildings — Ventilation for buildings — Part 13: Calculation of cooling systems (Module M4-8) — Generation (revision of EN 15243)

This is a free page sample. Access the full version online.

EN 15243	CEN/TR 16798–14	Energy performance of buildings — Ventilation for buildings — Part 14: Interpretation of the requirements in EN 16798-13 — Calculation of cooling systems (Module M4-8) — Generation (revision of EN 15243)
N/A	EN 16798–15	Energy performance of buildings — Ventilation for buildings — Part 15: Calculation of cooling systems (Module M4-7) — Storage
N/A	CEN/TR 16798–16	Energy performance of buildings — Ventilation for buildings — Part 16: Interpretation of the requirements in EN 16798-15 — Calculation of cooling systems (Module M4-7) — Storage
EN 15239, and EN 15240	EN 16798–17	Energy performance of buildings — Ventilation for buildings — Part 17: Guidelines for inspection of ventilation and air conditioning systems (Module M4-11, M5-11, M6-11, M7-11)
N/A	CEN/TR 16798–18	Energy performance of buildings — Ventilation for buildings — Part 18: Interpretation of the requirements in EN 16798-17 — Guidelines for inspection of ventilation and air-conditioning systems (Modules M4-11, M5-11, M6-11, M7-11)

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

This is a free page sample. Access the full version online.

Introduction

This European Standard is part of a series of standards aiming at international harmonization of the methodology for the assessment of the energy performance of buildings, called “set of EPB standards”.

All EPB standards follow specific rules to ensure overall consistency, unambiguity and transparency.

All EPB standards provide a certain flexibility with regard to the methods, the required input data and references to other EPB standards, by the introduction of a normative template in Annex A and Annex B with informative default choices.

For the correct use of this standard, a normative template is given in Annex A to specify these choices. Informative default choices are provided in Annex B.

The main target groups of this standard are all the users of the set of EPB standards (e.g. engineers, regulators, programmers).

Use by or for regulators: In case the standard is used in the context of national or regional legal requirements, mandatory choices may be given at national or regional level for such specific applications. These choices (either the informative default choices from Annex B or choices adapted to national / regional needs, but in any case following the template of this Annex A) can be made available as national annex or as separate (e.g. legal) document (national data sheet).

NOTE 1 So in this case:

— the regulators will **specify** the choices;

— the individual user will apply the standard to assess the energy performance of a building, and thereby **use** the choices made by the regulators.

Topics addressed in this standard can be subject to public regulation. Public regulation on the same topics can override the default values in Annex B of this standard. Public regulation on the same topics can even, for certain applications, override the use of this standard. Legal requirements and choices are in general not published in standards but in legal documents. In order to avoid double publications and difficult updating of double documents, a national annex may refer to the legal texts where national choices have been made by public authorities. Different national annexes or national data sheets are possible, for different applications.

It is expected, if the default values, choices and references to other EPB standards in Annex B are not followed due to national regulations, policy or traditions, that:

— national or regional authorities prepare data sheets containing the choices and national or regional values, according to the model in Annex A. In this case, the National Annex (e.g. NA) refers to this text;

— or, by default, the national standards body will consider the possibility to add or include a national Annex in agreement with the template of Annex A, in accordance to the legal documents that give national or regional values and choices.

Default references to EPB standards other than EN ISO 52000-1 are identified by the EPB module code number and given in Table B.1. If alternative references are specified, this should be done in Table NA.1 of a National Annex, which should follow the template given in Table A.1.

NOTE 2 Example of EPB module code number: M5–5, or M5–5.1 (if module M5–5 is subdivided), or M5–5/1 (if reference to a specific clause of the standard covering M5–5.

NOTE 3 The same module code numbering is bound to be used in other EPB standards. This will facilitate, in an individual country, the making of a consistent set of national annexes for each EPB standard and contribute to the overall consistency and transparency.

This is a free page sample. Access the full version online.

Further target groups are parties wanting to motivate their assumptions by classifying the building energy performance for a dedicated building stock.

More information is provided in the Technical Report accompanying this standard (CEN/TR 16798-6), including examples aiming to check the quality and usability of the standard.

CEN/TC 156 deals with ventilation and air conditioning systems in buildings. Subjects covered by CEN/TC 156 are:

1) energy performance calculation for ventilation, air conditioning and cooling systems;

2) inspection of ventilation and air conditioning systems; and

3) installation and commissioning of ventilation and air conditioning systems.

The revision includes changes:

— for a rearrangement of content versus EN 15242:2007, in order to better fit in the modular structure given in EN ISO 52000-1:2017;

— to cover ventilation systems which is intended for residential buildings (including air heating and air cooling definition, see the module M5-1 standard);

— for an improved fan energy calculation, taking into consideration control strategies according to CEN/TC 247 and fan product standards /data;

— for an improved calculation of heat recovery devices, delivering the efficiency and auxiliary energy depending on control;

— for the consideration of recirculation;

— the formatting according to the new rules set in CEN/TS 16629;

— the consideration of ISO/TC 205 work performed in the meantime.

This is a free page sample. Access the full version online.

1 Scope

This European Standard covers energy performance calculation of mechanical ventilation systems with integrated heating/cooling generation, including domestic hot water production, using a monthly or seasonal calculation interval or a bin method. It takes into account the generation (air handling unit) and distribution (duct system) parts. It does not cover the emission part (calculation of the required volume flow rates and/or supply air conditions), which is covered in the M5-5 standard. It does not include humidification and dehumidification. This method is focussed on small, packaged ventilation systems, typically used in residential buildings, although the application is not restricted on the basis of building or space use type.

A calculation method for mechanical ventilation and air conditioning systems, including humidification and dehumidification, using an hourly calculation interval or a bin method, is provided in a separate standard, EN 16798-5-1.

Table 1 shows the relative position of this standard within the set of EPB standards in the context of the modular structure as set out in EN ISO 52000-1.

NOTE 1 In CEN ISO/TR 52000-2, the same table can be found, with, for each module, the numbers of the relevant EPB standards and accompanying technical reports that are published or in preparation.

NOTE 2 The modules represent EPB standards, although one EPB standard might cover more than one module and one module might be covered by more than one EPB standard, for instance a simplified and a detailed method respectively. See also Clause 2 and Tables A.1 and B.1.

This is a free page sample. Access the full version online.

Table 1 — Position of this standard (in casu M5–6, M5–8) within the EPB set of standards

	Overarching	Building (as such)	Technical Building Systems									
Submodule	**Descriptions**	**Descriptions**	**Descriptions**	**Heating**	**Cooling**	**Ventilation**	**Humidification**	**Dehumidification**	**Domestic Hot water**	**Lighting**	**Building automation and control**	**PV, wind, ...**
sub1	**M1**	**M2**		**M3**	**M4**	**M5**	**M6**	**M7**	**M8**	**M9**	**M10**	**M11**
1	General	General	General									
2	Common terms and definitions; symbols, units and subscripts	Building Energy Needs	Needs								a	
3	Applications	(Free) Indoor Conditions without Systems	Maximum Load and Power									
4	Ways to Express Energy Performance	Ways to Express Energy Performance	Ways to Express Energy Performance									
5	Building categories and Building Boundaries	Heat Transfer by Transmission	Emission and control									
6	Building Occupancy and Operating Conditions	Heat Transfer by Infiltration and Ventilation	Distribution and control			EN 16798–5-2						
7	Aggregation of Energy Services and Energy Carriers	Internal Heat Gains	Storage and control									

This is a free page sample. Access the full version online.

	Overarching	Building (as such)	Technical Building Systems									
Submodule	**Descriptions**	**Descriptions**	**Descriptions**	**Heating**	**Cooling**	**Ventilation**	**Humidification**	**Dehumidification**	**Domestic Hot water**	**Lighting**	**Building automation and control**	**PV, wind, ...**
sub1	**M1**	**M2**		**M3**	**M4**	**M5**	**M6**	**M7**	**M8**	**M9**	**M10**	**M11**
8	Building zoning	Solar Heat Gains	Generation and control			EN 16798–5-2						
9	Calculated Energy Performance	Building Dynamics (thermal mass)	Load dispatching and operating conditions									
10	Measured Energy Performance	Measured Energy Performance	Measured Energy Performance									
11	Inspection	Inspection	Inspection									
12	Ways to Express Indoor Comfort		BMS									
13	External Environment Conditions											
14	Economic Calculation											

[a] The shaded modules are not applicable.

SAI GLOBAL

This is a free preview. Purchase the entire publication at the link below:

Product Page

Looking for additional Standards? Visit Intertek Inform Infostore

Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation