

AS 1482—1985

Australian Standard<sup>®</sup>

---

**Electrical equipment for  
explosive atmospheres—  
Protection by ventilation—Type  
of protection v**

---

This Australian standard was prepared by Committee EL/14, Electrical Equipment in Hazardous Locations. It was approved on behalf of the Council of the Standards Association of Australia on 14 August 1985, and published on 4 October 1985.

---

The following interests are represented on Committee EL/14:

Australian Coal Association  
Australian Electrical and Electronic Manufacturers Association  
Australian Institute of Petroleum  
Confederation of Australian Industry  
Department of Industrial Relations, N.S.W.  
Department of Defence Support  
Department of Minerals and Energy, Vic.  
Department of Mines, Qld  
Electrical Contractors Associations of Australia  
Electricity Supply Association of Australia  
Independent testing interests  
Insurance Council of Australia  
State electricity regulatory authorities

---

**Review of Australian Standards.** To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

AS 1482—1985

Australian Standard<sup>®</sup>

---

**ELECTRICAL EQUIPMENT FOR  
EXPLOSIVE ATMOSPHERES—  
PROTECTION BY VENTILATION—  
TYPE OF PROTECTION v**

---

First published	.....	1973
Second edition	.....	1985

PUBLISHED BY STANDARDS AUSTRALIA  
(STANDARDS ASSOCIATION OF AUSTRALIA)  
1 THE CRESCENT, HOMEBUSH, NSW 2140

ISBN 0 7262 3907 0

## PREFACE

This edition of this standard was prepared by the Association's Committee on Electrical Equipment for Hazardous Locations and it supersedes AS 1482-1973, Protection by Ventilation of Electrical Equipment for Explosive Atmospheres. It is one of a series of standards dealing with the use of electrical equipment in explosive atmospheres.

The standard deals with ventilation of buildings and rooms by gas or vapour dilution. In particular it deals with the control of environmental gases and vapours such that equipment not normally allowed in a Zone 1 area may be used.

This edition is technically identical to the 1973 edition.

The main reason for this new edition was for the purpose of correcting cross-references to other standards. However, the opportunity was used to update some clauses in this standard in line with current standards writing practice.

## CONTENTS

	<i>Page</i>
SECTION 1 VENTILATION OF BUILDINGS AND ROOMS—GAS OR VAPOUR DILUTION	
1.1 Scope . . . . .	3
1.2 Referenced Documents . . . . .	3
1.3 Definitions . . . . .	3
1.4 Ventilation of Buildings and Rooms . . . . .	3
1.5 Tests . . . . .	6
SECTION 2 VENTILATION OF ELECTRICAL POWER EQUIPMENT—HEAT DISSIPATION	
2.1 General . . . . .	7
2.2 Basic Principles . . . . .	7
2.3 Definitions . . . . .	7
2.4 Electrical Safety Requirements . . . . .	7
2.5 Temperature Classification . . . . .	7
2.6 Design and Construction . . . . .	7
2.7 Tests . . . . .	10
APPENDICES	
A Environmental Control of Flammable Gases and Vapours . . . . .	11
B General Description of Normal Routine Testing . . . . .	19

### © Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

## STANDARDS ASSOCIATION OF AUSTRALIA

## Australian Standard

## for

**ELECTRICAL EQUIPMENT FOR EXPLOSIVE ATMOSPHERES—PROTECTION BY VENTILATION TYPE OF PROTECTION v**

## SECTION 1. VENTILATION OF BUILDINGS AND ROOMS—GAS OR VAPOUR DILUTION

**1.1 SCOPE.** This standard sets out requirements for the protection by ventilation of electrical equipment in explosive atmospheres. The standard is in two Sections, as follows:

- (a) Section 1—Ventilation of Buildings and Rooms—Gas or Vapour Dilution.
- (b) Section 2—Ventilation of Electrical Power Equipment—Heat Dissipation.

Section 1 of this standard relates to the requirements of dilution ventilation and point-extraction ventilation of buildings and rooms.

**1.2 REFERENCED DOCUMENTS.** The following standards are referred to in this standard:

AS 1020	SAA Static Electricity Code
AS 1021	Protection by Purging of Electrical Equipment for Explosive Atmospheres
AS 1825	Electrical Equipment for Explosive Atmospheres—Pressurized Enclosures—Type of Protection p
AS 2380	Electrical Equipment for Explosive Gas Atmospheres—Explosion Protection Techniques Part 1—General Requirements
AS 2430	Classification of Hazardous Areas Part 1—Explosive Gas Atmospheres
AS 3000	SAA Wiring Rules
AS 3100	Approval and Test Specification for Definitions and General Requirements for Electrical Materials and Equipment
NFPA 325M	Fire Hazard Properties of Flammable Liquids, Gases and Volatile Solids

**1.3 DEFINITIONS.** For the purpose of this Section the following definitions apply:

**1.3.1 Capture velocity**—the minimum air velocity required at the point of origin to capture the hazardous gas or vapour effectively.

**1.3.2 Dilution ventilation**—a process of supplying an area or room with fresh air (or an inert gas) at sufficient flow to reduce to an acceptably safe level the concentration of any flammable gases and vapours initially present, and to maintain this safe level by the supply of a sufficient volume of fresh air.

**1.3.3 Fresh air**—air drawn from an atmosphere which is free from flammable gases or vapours, dusts or fibres.

**1.3.4 Ignition temperature**—the minimum temperature required to ignite or cause independent self-sustained (air) combustion of a solid, liquid or gaseous substance.

**1.3.5 Inadequately ventilated area**—an area where there are obstacles to the free and natural diffusion of gases and vapours and where there is insufficient ventilation.

**1.3.6 Mechanically ventilated area**—an area where uncontaminated air is continuously introduced in sufficient quantity to prevent the formation of an explosive gas-air mixture.

NOTE: An extraction system may achieve the same result provided that the entering air is uncontaminated.

**1.3.7 Naturally ventilated area**—an area where there are no obstacles to free natural diffusion of gases and vapours likely to be released in the atmosphere, such as—

- (a) outdoor situations; or
- (b) a building, room or space substantially open, and free from obstruction.

**1.3.8 Safety device**—a device provided to protect a system against conditions which could result in fire or explosion.

NOTE: An essential requirement of any safety device when used in a co-ordinated assembly is that the system should 'fail-safe'.

**1.4 VENTILATION OF BUILDINGS AND ROOMS**

**1.4.1 General description.** Ventilation should be regarded as the first line of defence against the formation of an explosive concentration of gas or vapour. Recourse to its adoption as an acceptable and sole method of protection shall, however, be subject to the following considerations:

- (a) The conditions shall be such as to avoid the possibility of the liberation, accidental or otherwise, of an abnormal volume of gas, or liquid from giving rise to flammable concentrations of any gas or vapour.
- (b) The ambient atmosphere in the hazardous location shall be pre-ventilated to reduce the concentration of the gas or vapour to less than 50 percent of the lower explosion limit before the electrical equipment can be energized.
- (c) Where ventilation of the point-extraction type is adopted, the inlet shall be situated as near as possible to any point where the escape of vapour or liquid may occur. The whole of the

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

- 
- Looking for additional Standards? Visit Intertek Inform Infostore
  - Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation
-