

AS/NZS 4645.2:2008

AS/NZS 4645.2:2008

Australian/New Zealand Standard™

**Gas distribution networks**

**Part 2: Steel pipe systems**



## **AS/NZS 4645.2:2008**

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee AG-008, Gas Distribution. It was approved on behalf of the Council of Standards Australia on 16 December 2008 and on behalf of the Council of Standards New Zealand on 5 December 2008.

This Standard was published on 31 December 2008.

---

The following are represented on Committee AG-008:

Australian Pipeline Industry Association Ltd  
Engineers Australia  
Energy Networks Association  
Gas Association New Zealand  
Gas Technical Regulators Committee  
LPG Australia  
New Zealand Institute of Gas Engineers  
Plastics Industry Pipe Association  
Welding Technology Institute of Australia

---

### **Keeping Standards up-to-date**

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at [www.standards.com.au](http://www.standards.com.au) or Standards New Zealand web site at [www.standards.co.nz](http://www.standards.co.nz) and looking up the relevant Standard in the on-line catalogue.

Alternatively, both organizations publish an annual printed Catalogue with full details of all current Standards. For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

---

AS/NZS 4645.2:2008

Australian/New Zealand Standard™

## **Gas distribution networks**

### **Part 2: Steel pipe systems**

Originated as AS 1697—1981,  
Second edition 2005.  
Jointly revised and redesignated as AS/NZS 4645.2:2008.

#### **COPYRIGHT**

© Standards Australia/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Jointly published by Standards Australia, GPO Box 476, Sydney, NSW 2001 and Standards New Zealand, Private Bag 2439, Wellington 6020

ISBN 0 7337 8990 0

## PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee AG-008, Gas Distribution, through its subcommittee AG-008-02, Installation and Maintenance of Steel Pipe Systems for Gas, to supersede AS 1697—2005, *Installation and maintenance of steel pipe systems for gas*.

The intent of this Standard is to provide for the protection of the general public, gas distribution network operating personnel and the environment, and to ensure safe and reliable operation of gas distribution networks that reticulate gas to consumers.

It covers steel piping within gas distribution networks covered by AS/NZS 4645.1, where the maximum allowable operating pressures up to or equal to 1050 kPa and the hoop stress is less than or equal to 20% SMYS of the pipe. Steel piping systems for gas outside these limits are generally covered by the AS 2885 suite of Standards and for some jurisdictions. AS/NZS 4645.1 provides for limited use up to 1965 kPa.

Users of the Standard should note that AS 4645—2005 *Gas distribution network management*, AS 4568—2005 *Preparation of a safety and operating plan for gas networks*, AS 1697—2005 *Installation and maintenance of steel pipe systems for gas* and AS 3723—1989 *Installation and maintenance of plastic pipes systems for gas* have been revised and reissued as parts of AS/NZS 4645 *Gas distribution networks*.

This series of Standards includes the following parts:

### AS/NZS

4645	Gas distribution networks
4645.1	Part 1: Network management
4645.2	Part 2: Steel pipe systems
4645.3	Part 3: Plastics pipe systems

AS/NZS 4645.1 provides a risk-based framework for management of a gas distribution network and identifies the high-level safety requirements for all stages in the life-cycle of a gas distribution network.

AS/NZS 4645.2 is to be used in conjunction with AS/NZS 4645.1 and covers design, materials, construction, testing and commissioning of steel mains and services within a network to provide a means of compliance for aspects of a gas distribution network required by AS/NZS 4645.1.

This Standard achieves its purpose through five fundamental principles as follows:

- (a) A gas distribution network shall be designed and constructed to have sufficient controls to withstand the threats to which it may be subjected during construction, testing and operation.
- (b) Before a gas distribution network is placed into operation it shall be inspected and tested to prove its integrity.
- (c) Important matters relating to safety, engineering design, materials, testing, operation and inspection shall be reviewed, documented and approved in accordance with the Safety and Operating Plan.
- (d) Operations and maintenance shall provide for continued monitoring and safe operation of the gas distribution network.
- (e) Where changes occur in or to a gas distribution network, which alter the design assumptions or affect the original integrity, appropriate steps shall be taken to assess the changes, to ensure continued safe operation of the network.

The Standard is not a design handbook, nor a manual on distribution practices. It does not remove the need for qualified and experienced engineering design, installation and operation or for competent engineering judgment, and does require interpretation and implementation by competent engineers.

Statements in this Standard expressed in mandatory terms are deemed to be mandatory only for claiming compliance with this Standard. Alternative means of compliance may be acceptable provided the required safety outcomes can be demonstrated with AS/NZS 4645.1.

The Australian and New Zealand Technical Regulators have advised that this Standard will only apply to the life cycle of new gas distribution networks and modifications or augmentations to existing assets within gas distribution networks. However, the sections on operations, maintenance, repair, decommissioning, gas quality and risk assessment may be suitable for application to existing assets in existing networks.

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the appendix to which they apply. A ‘normative’ appendix is an integral part of a Standard, whereas an ‘informative’ appendix is only for information and guidance.

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

- 
- Looking for additional Standards? Visit Intertek Inform Infostore
  - Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation
-