



The storage and handling of liquefied natural gas



This Australian Standard® was prepared by Committee ME-070, Liquefied Natural Gas Storage and Handling. It was approved on behalf of the Council of Standards Australia on 9 February 2017.

This Standard was published on 13 March 2017.

The following are represented on Committee ME-070:

- Australasian Fire and Emergency Service Authorities Council
 - Australian Chamber of Commerce and Industry
 - Australian Industry Group
 - Australian Pipelines and Gas Association
 - Gas Energy Australia
 - Gas Technical Regulators Committee
-

This Standard was issued in draft form for comment as DR AS 3961:2016.

Standards Australia wishes to acknowledge the participation of the expert individuals that contributed to the development of this Standard through their representation on the Committee and through the public comment period.

Keeping Standards up-to-date

Australian Standards® are living documents that reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued.

Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments that may have been published since the Standard was published.

Detailed information about Australian Standards, drafts, amendments and new projects can be found by visiting **www.standards.org.au**

Standards Australia welcomes suggestions for improvements, and encourages readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at **mail@standards.org.au**, or write to Standards Australia, GPO Box 476, Sydney, NSW 2001.

AS 3961:2017

Australian Standard®

The storage and handling of liquefied natural gas

Originated as AS 3961—1991.
Previous edition 2005.
Third edition AS 3961:2017.

COPYRIGHT

© Standards Australia Limited

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968.

Published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001, Australia

ISBN 978 1 76035 696 5

PREFACE

This Standard was prepared by the Standards Australia Committee ME-070, Liquefied Natural Gas Storage and Handling, to supersede AS 3961—2005.

The objective of this Standard is to provide requirements for the design, construction and operation of installations for the storage and handling of liquefied natural gas (LNG), covering installations of atmospheric-type tanks for supplying marine terminals, pipeline peak shaving, and pressure tanks.

The LNG industry has developed considerably since the previous editions and this edition draws upon this experience. Requirements that were modelled on the storage of LP Gas and flammable liquids have been rewritten to reflect the properties and usage of LNG.

Changes have included the following:

- (a) Removal of requirements for pressure storages of less than 5 m³ as small storages are not in use in the industry and the cryogenic properties of LNG are such that small storage is generally not practical.
- (b) Reinforcing the containment and separation aspects of firefighting as the use of water sprays can exacerbate a fire situation.
- (c) Removing requirements that are in the scope of other standards and are adequately covered in those standards. Examples are pressure vessel requirements in the scope of AS 1210, *Pressure vessels*, and transport requirements in the scope of the ADG Code and AS 2809, *Road tank vehicles for dangerous goods*, Parts 1 and 6.
- (d) Revision of the fill coupling requirements to align with International Standards and allow for the use of dry-break couplings.

Statements expressed in mandatory terms in notes to tables are deemed to be requirements of this Standard.

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the appendix to which they apply. A ‘normative’ appendix is an integral part of a Standard, whereas an ‘informative’ appendix provides information and guidance only.

CONTENTS

	<i>Page</i>
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE AND APPLICATION	5
1.2 REFERENCED DOCUMENTS	5
1.3 DEFINITIONS	5
SECTION 2 GENERAL INSTALLATION REQUIREMENTS	
2.1 SCOPE OF SECTION	9
2.2 TANKS	9
2.3 PRESSURE AND VACUUM RELIEF	9
2.4 GAUGES AND CONTROLS	10
2.5 PLANT EMERGENCY SHUTDOWN SYSTEMS	11
2.6 LOCATIONS	11
2.7 POTENTIAL FLAME IMPINGEMENT	15
2.8 ROAD AND RAIL TANKER TRANSFER INSTALLATIONS	15
2.9 PIPING, VALVES AND ACCESSORIES	17
2.10 INSULATION	19
2.11 VAPORIZER DESIGN AND CONSTRUCTION	19
2.12 VAPORIZER INSTALLATION	19
2.13 SECURITY AND DAMAGE PROTECTION	20
2.14 EARTHING AND BONDING	20
2.15 PERSONAL PROTECTIVE EQUIPMENT	21
2.16 ODORIZERS	21
2.17 MARKINGS AND NOTICES	21
2.18 LIGHTING	21
SECTION 3 PRESSURE TANK STORAGES	
3.1 SCOPE OF SECTION	22
3.2 TANK DESIGN AND CONSTRUCTION	22
3.3 CONTROLS OF LNG OUTFLOWS	22
3.4 LOCATION AND INSTALLATION	23
SECTION 4 ATMOSPHERIC TANK STORAGES	
4.1 SCOPE OF SECTION	24
4.2 TANK DESIGN AND CONSTRUCTION	24
4.3 GAUGES AND CONTROLS	24
4.4 LOCATION AND INSTALLATION	25
4.5 SPILLAGE CONTAINMENT AND CONTROL	25
4.6 MARINE TRANSFER INSTALLATIONS	27
SECTION 5 AUTOMOTIVE REFUELLING STATIONS	
5.1 SCOPE OF SECTION	29
5.2 CONTROL OF IGNITION SOURCES	29
5.3 TANK AND PIPING	29
5.4 FILLING AREA	29
5.5 DISPENSERS	30
5.6 NOTICES, SIGNS, AND INSTRUCTIONS	31

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- Looking for additional Standards? Visit Intertek Inform Infostore
 - Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation
-