

WITHDRAWN: 19980205

SUPERSEDED BY:

AS 3500.1—1992

AS/NZS 3500.1.2:1998 (published 19980205)

Australian Standard®

**National Plumbing and Drainage
Code**

Part 1: Water supply

First published as AS 3500.1—1990.
Second edition 1992.

**PUBLISHED BY STANDARDS AUSTRALIA
(STANDARDS ASSOCIATION OF AUSTRALIA)
STANDARDS HOUSE, 80 ARTHUR ST, NORTH SYDNEY NSW
ISBN 0 7262 7945 5**

This Australian Standard was prepared by Committee WS/14, National Plumbing and Drainage Code. It was approved on behalf of the Council of Standards Australia on 30 October 1992 and published on 21 December 1992.

The following interests are represented on Committee WS/14:

Association of Hydraulic Services Consultants Australia
AUSTAP
Australian Clay Pipe Manufacturers Association
Australian Local Government Engineers Association
Brisbane City Council
Department of Lands and Housing, N.T.
Engineering and Water Supply Department, S.A.
Federated Master Plumbers of Australia
Local Government Office, Tas.
Master Plumbers Association of South Australia
Melbourne Water
Metal Trades Industry Association of Australia
Plastics Institute of Australia
Public Works Department, N.S.W.
Queensland Water Resources Commission
Royal Melbourne Institute of Technology
Water Authority of Western Australia
Water Board, Sydney—Illawarra—Blue Mountains

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

STANDARDS AUSTRALIA

Amendment No. 1 to AS 3500.1—1992 National Plumbing and Drainage Code Part 1: Water supply

REVISED TEXT

The 1992 edition of AS 3500.1 is amended as follows; the amendment(s) should be inserted in the appropriate place.

SUMMARY: This Amendment applies to Clause 5.2 and Clause 5.3.1.

Published on 5 March 1995.

AMDT
No. 1
MAR.
1995

Page 27 Clause 5.2

Delete existing Clause and substitute:

5.2 ELECTRICAL SAFETY PRECAUTIONS EARTHING Before any existing metallic water service pipe, which forms part of an earth electrode for an electrical installation, is cut or uncoupled, the following precautions shall be taken to reduce the risk of electrical shock:

- (a) The main switch or switches on the premises shall be switched off and a tag reading 'DANGER DO NOT CLOSE' attached over the switch.
- (b) A bridging conductor, fitted with suitable clamps and having a current rating of not less than 70 A, shall be connected across the intended gap.
- (c) The pipe shall be cleaned to bare metal where the clamps are to be connected.
- (d) The electrical bridge shall not be broken or removed until all work on the water service is completed and continuity of the metallic service pipe is restored.
- (e) Where any existing metallic service pipe is to be replaced in part or in its entirety by plastic pipe or other non-metallic fittings or couplings, the work shall not commence until the earthing requirements have been checked by an electrical contractor and modified, if necessary.



AMDT
No. 1
MAR.
1995

Page 27 Clause 5.3.1

Delete existing Clause and substitute:

5.3.1 Electrical cables and gaspipes

5.3.1.1 Water services Above- and below-ground water services shall be installed so that—

- (a) no potential safety hazard is created when in close proximity to other services; and
- (b) access for maintenance and potential branch insertions is not impaired by the other services.

5.3.1.2 Crossover Any below-ground crossover of a water service shall—

- (a) cross at an angle of not less than 45°;
- (b) have a vertical separation of not less than 100 mm.
- (c) be suitably marked with bricks or warning tape.

NOTES:

- 1 The proximity to other services will vary, depending on the type and size of the services affected.
 - 2 For shared trenching, an Australian Standard is in course of preparation.
-

STANDARDS AUSTRALIA

Amendment No. 2
to
AS 3500.1—1992
National Plumbing and Drainage Code
Part 1: Water supply

REVISED TEXT

The 1992 edition of AS 3500.1 is amended as follows; the amendments should be inserted in the appropriate place.

SUMMARY: This Amendment applies to Table 4.2, Table 4.3, Figure 4.4 and Figure 7.6.

Published on 5 May 1996.

AMDT
No. 2
MAY
1996

Page 19 Table 4.2

In first column under 'HOSE ATTACHMENT OUTLETS' *add* new Item (c).

- | | | |
|---|-----|---------------------|
| (c) Hose taps located within 18 m of
a Type C system | Low | Non-testable device |
|---|-----|---------------------|

Existing Item (c) becomes (d).

AMDT
No. 2
MAY
1996

Page 20 Table 4.3

In first column *delete* 'FIRE HYDRANT OR FIRE SPRINKLER SERVICES' and *substitute* 'FIRE SERVICES' and *add* new Item (b).

- | | | |
|--|--------|-----|
| (b) Fire hose reels, where there is a
potential to be used for purposes
other than fire fighting | Medium | DCV |
|--|--------|-----|

Existing Item (b) becomes (c) and existing Item (c) becomes (d).

AMDT
No. 2
MAY
1996

Page 24 Figure 4.4

Delete '150 mm' and *substitute* '300 mm'.

AMDT
No. 2
MAY
1996

Page 41 Figure 7.6

Delete 'Double-check valve', and *substitute* 'RPZD'.



This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- Looking for additional Standards? Visit Intertek Inform Infostore
 - Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation
-