

SUPERSEDED BY *AS/NZS 1260:1996*

Australian Standard[®]

**Unplasticized PVC (UPVC) pipes
and fittings for sewerage
applications**

Part 5: Pipes with structured walls

[Defence Title allocated by Codification and Standardisation Authority:
PIPE, NON-METALLIC, RIGID]



This Australian Standard was prepared by Committee PL/21, Unplasticized PVC Pipes. It was approved on behalf of the Council of Standards Australia on 24 February 1993 and published on 17 May 1993.

The following interests are represented on Committee PL/21:

CSIRO Division of Building, Construction and Engineering
Engineering and Water Supply Department, S.A.
Melbourne Water
Public Works Department, N.S.W.
Rural Water Commission, Vic.
The Plastics Industry Association
Water Authority of Western Australia
Water Board, Sydney—Illawarra—Blue Mountains

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

AS 1260.5—1993

Australian Standard®

**Unplasticized PVC (UPVC) pipes
and fittings for sewerage
applications**

Part 5: Pipes with structured walls

First published as AS 1260.5—1993.

PUBLISHED BY STANDARDS AUSTRALIA
(STANDARDS ASSOCIATION OF AUSTRALIA)
1 THE CRESCENT, HOMEBUSH, NSW 2140

ISBN 0 7262 8097 6

PREFACE

This Standard was prepared by the Standards Australia Committee on Unplasticized PVC Pipes, as part of the AS 1260 series which specifies the material and performance requirements for unplasticized PVC pipes and fittings for sewerage applications.

This Standard is modelled on AS 1260.1, *Unplasticized PVC (UPVC) pipes and fittings for sewerage applications*, Part 1: *Pipes*, except that the pipes are classified in terms of pipe stiffness. Nominal size 100 has a pipe stiffness equivalent to Class SH, whereas for the larger sizes the pipe stiffness is equivalent to Class SEH.

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

CONTENTS

Page

SECTION 1 SCOPE AND GENERAL

1.1	SCOPE	4
1.2	REFERENCED DOCUMENTS	4
1.3	DEFINITIONS	4
1.4	NOTATION	5
1.5	STORAGE AND TRANSPORT	5
1.6	MARKING	5

SECTION 2 MATERIAL REQUIREMENTS

2.1	TYPE AND CLASSIFICATION	6
2.2	COMPOSITION	6
2.3	COLOUR	6
2.4	FREEDOM FROM DEFECTS	6
2.5	ELASTOMERIC JOINTING RINGS	6

SECTION 3 DIMENSIONAL REQUIREMENTS

3.1	DIAMETER	7
3.2	WALL THICKNESS	7
3.3	LENGTH	7
3.4	PIPE SPIGOT ENDS	7
3.5	SOCKETS FORMED ON PIPE ENDS	7
3.6	SOLVENT CEMENT JOINT GEOMETRY	7

SECTION 4 TEST REQUIREMENTS

4.1	FLATTENING	11
4.2	IMPACT CHARACTERISTICS AT 20°C	11
4.3	SOFTENING POINT	11
4.4	BOND STRENGTH	11
4.5	PIPE STIFFNESS	11
4.6	RING FLEXIBILITY TEST	12
4.7	LIQUID INFILTRATION	12
4.8	RESISTANCE TO ROOT PENETRATION	12

APPENDICES

A	DETERMINATION OF BOND STRENGTH	13
B	DETERMINATION OF PIPE STIFFNESS	14
C	RING FLEXIBILITY TEST	19

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- Looking for additional Standards? Visit Intertek Inform Infostore
 - Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation
-