This is a free page sample. Access the full version online.

AS 1684.2 N1/N2 Supp 13—2006

AS 1684.2 N1/N2 Supplement 13—2006

Residential timber-framed construction

Part 2: Non-cyclonic areas
N1/N2 Supplement 13: Timber framing span tables—Wind classification N1/N2—Unseasoned hardwood—Stress Grade F11
(Supplement to AS 1684.2—2006)

STANDARDS
Australia

This is a free page sample. Access the full version online.

This Australian Standard Supplement was prepared by Committee TM-002, Timber Framing. It was approved on behalf of the Council of Standards Australia on 9 November 2005.
This Supplement was published on 31 January 2006.

The following are represented on Committee TM-002:

A3P
Association of Consulting Engineers, Australia
Australian Building Codes Board
Building Research Association of New Zealand
CSIRO Manufacturing and infrastructures Technology
Engineered Wood Products Association of Australasia
Engineers Australia
Forest Industries Federation (WA)
Housing Industry Association
Master Builders, Australia
New Zealand Forest Industries Council
New Zealand Timber Industry Federation
Scion
South Australian Housing Trust
Structural Engineered Timber Manufactures Association, New Zealand
Timber and Building Materials Association, NSW
Timber Development Association, NSW
Timber Development Association of South Australia
Timber Queensland

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Web Shop at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Global Standard*, has a full listing of revisions and amendments published each month.

Australian Standards™ and other products and services developed by Standards Australia are published and distributed under contract by SAI Global, which operates the Standards Web Shop.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to the Chief Executive, Standards Australia, GPO Box 476, Sydney, NSW 2001.

This is a free page sample. Access the full version online.

AS 1684.2 N1/N2 Supplement 13—2006

Residential timber-framed construction

Part 2: Non-cyclonic areas N1/N2 Supplement 13: Timber framing span tables—Wind classification N1/N2—Unseasoned hardwood—Stress Grade F11 (Supplement to AS 1684.2—2006)

Originated as AS 1684 Supp 5—1975.
Second edition 1992.
Revised and redesignated as AS 1684.2 N1/N2 Supp 13—1999.
Third edition 2006.

COPYRIGHT

© Standards Australia

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia GPO Box 476, Sydney, NSW 2001, Australia

ISBN 0 7337 7112 2

This is a free page sample. Access the full version online.

LIST OF TABLES

SINGLE OR UPPER STOREY

1 FLOOR BEARERS – Supporting single or upper storey loadbearing walls – FLW 1200
2 FLOOR BEARERS – Supporting single or upper storey loadbearing walls – FLW 2400
3 FLOOR BEARERS – Supporting single or upper storey loadbearing walls – FLW 3600
4 FLOOR BEARERS – Supporting single or upper storey loadbearing walls – FLW 4800
5 FLOOR BEARERS – Supporting floor load only
6 FLOOR JOISTS
7 WALL STUDS – Not notched single or upper storey
8 WALL STUDS – Notched 20 mm single or upper storey
9 STUDS SUPPORTING CONCENTRATED LOADS – Not notched
10 STUDS SUPPORTING CONCENTRATED LOADS – Notched to 20 mm
11 JAMB STUDS – Single or upper storey
12 INTERNAL LOADBEARING WALL STUDS – Not notched single or upper storey
13 INTERNAL LOADBEARING WALL STUDS – Notched to 20 mm single or upper storey
14 BOTTOM PLATES - Supporting single or upper storey
15 TOP PLATES – Single or upper storey sheet roof
16 TOP PLATES - Single or upper storey tile roof
17 LINTELS – Sheet roof – Single or upper storey loadbearing walls
18 LINTELS – Tile roof – Single or upper storey loadbearing walls
19 LINTELS – Sheet roof – Supporting concentrated roof loads
20 LINTELS – Tile roof – Supporting concentrated roof loads
21 CEILING JOISTS – Supporting ceiling loads, no overbatten
22 CEILING JOISTS – Supporting ceiling loads with overbatten
23 HANGING BEAMS – Supporting ceiling loads
24 COUNTER BEAMS
25 STRUTTING/HANGING BEAMS – Supporting roof & ceiling loads
26 STRUTTING/COUNTER BEAMS – Supporting roof & ceiling loads
27 STRUTTING BEAMS
28 UNDERPURLINS
29 RAFTERS OR PURLINS
30 RIDGE OR INTERMEDIATE BEAMS – Single span
31 RIDGE OR INTERMEDIATE BEAMS – Continuous span
32 ROOF BATTENS – Supporting roofing only

LOWER STOREY OF TWO STOREY

33 FLOOR BEARERS – Supporting two storey loadbearing walls – FLW 1800
34 FLOOR BEARERS – Supporting two storey loadbearing walls – FLW 3600
35 FLOOR BEARERS – Lower Storey of two storey supporting upper and lower floor loads only
36 WALL STUDS – Not notched lower storey loadbearing walls
37 WALL STUDS - Notched to 20 mm lower storey loadbearing walls
38 STUDS – Not notched – Supporting concentrated floor loads
39 STUDS – Notched to 20 mm – Supporting concentrated floor loads
40 JAMB STUDS – Lower storey of two storey – FLW 1800
41 JAMB STUDS – Lower storey of two storey – FLW 3600
42 JAMB STUDS – Lower storey of two storey – FLW 4800
43 WALL STUDS - Not notched supporting floor loads only
44 WALL STUDS - Notched to 20 mm supporting floor loads only
45 BOTTOM PLATES – Lower storey of two storey
46 TOP PLATES – Lower storey of two storey
47 LINTELS – Lower storey loadbearing walls – Sheef roof
48 LINTELS – Lower storey loadbearing walls – Tile roof

VERANDAHS, POSTS & DECKS

49 DECK BEARERS
50 DECK JOISTS
51 VERANDAH BEAMS – Single span
52 VERANDAH BEAMS – Continuous span
53 POSTS SUPPORTING ROOF AND/OR FLOOR LOADS

COPYRIGHT

This is a free page sample. Access the full version online.

TABLE 1 FLOOR BEARERS - Floor load width 1200 mm Supporting single or upper storey loadbearing walls

Roof Load Width (mm)	1500		4500		7500		1500		4500		7500	
Size DxB (mm)	Maximum Bearer Span (mm)											
	Span	Cantilever	Span	Cantilever	Span	Cantilever	Span	Cantilever	Span	Cantilever	Span	Cantilever
	Single Span						Continuous Span					
Sheet Roof												
100x75	1300	300	1100	300	1000	300	1800	500	1600	400	1400	400
125x75	1700	500	1400	400	1300	300	2300	600	2000	600	1800	500
150x75	2000	600	1700	500	1600	400	2700	800	2300	600	2100	600
175x75	2300	600	2000	600	1800	500	3200	900	2700	800	2500	700
200x75	2700	800	2300	600	2100	600	3600	1000	3100	900	2800	800
225x75	3000	900	2600	700	2400	700	4000	1200	3500	1000	3200	900
250x75	3300	900	2900	800	2600	700	4300	1200	3800	1100	3600	1000
275x75	3700	1100	3200	900	2900	800	4600	1300	4100	1200	3800	1100
300x75	3900	1100	3500	1000	3100	900	4900	1400	4400	1300	4100	1200
Tile Roof												
100x75	1200	300	1000	300	NS	NS	1600	400	1300	300	1100	300
125x75	1500	400	1200	300	1100	300	2000	600	1600	400	1400	400
150x75	1800	500	1500	400	1300	300	2500	700	2000	600	1700	500
175x75	2100	600	1700	500	1500	400	2900	800	2300	600	2000	600
200x75	2400	700	2000	600	1700	500	3300	900	2600	700	2300	600
225x75	2700	800	2200	600	1900	500	3700	1100	3000	900	2600	700
250x75	3000	900	2400	700	2100	600	4000	1200	3300	900	2900	800
275x75	3300	900	2700	800	2400	700	4300	1200	3600	1000	3200	900
300x75	3600	1000	2900	800	2600	700	4600	1300	3900	1100	3500	1000

NOTES:

i) Maximum bearer spans supporting roof loads are based on the support of a maximum total sheet roof, framing and ceiling mass of 40 kg/m^2, a maximum total tile roof, framing and ceiling mass of 90 kg/m^2 and a maximum flooring mass of 40 kg/m^2. For guidance on determination of roof mass refer to Appendix B.

ii) Cantilevers shall not exceed 50% of actual backspan.

iii) Minimum bearing length = 50 mm at end supports and 100 mm at internal supports for continuous members.

iv) Multiple members shall be nailed together as per Clause 2.3.

v) For design parameters refer to Figure 4.6.

vi) Where loadbearing walls are supported at right angles to bearer within the bearer span reference should be made to Clause 4.3.1.5.

vii) Where bearers support roof point loads, reference should be made to Clause 4.3.1.6.

COPYRIGHT

SAI GLOBAL

This is a free preview. Purchase the entire publication at the link below:

Product Page

Looking for additional Standards? Visit Intertek Inform Infostore

Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation